



# CHINMAYA VIDYALAYA

(School With A Difference)


Affiliated to CBSE, Affn. No. 3630042

(Under the management of : Chinmaya Seva Trust, Hyderabad)

SANDEEPANY KAILAS, KUNDANBAGH, BEGUMPET,

HYDERABAD - 500 016. Phone : 23418012

E-mail : chinmayavidyalaya\_hyd@yahoo.co.in



5

Date: 21/10/2019

To  
The Director,  
Enforcement Vigilance & Disaster Mgmt,  
Buddabavan,  
Hyderabad.

Sir,

Sub:- Submission of Self certification of Fire Safety Measures - Reg  
Ref: G.O. Ms.No. 56, Home (Ser.IV) Department, dt; 26-07-2019

With reference to the above ref. we are hereby submitting the self certification of fire safety measures of our vidyalaya for the purpose of affiliation.

Hence, I request you to kindly accept our letter and acknowledge the same.

Thanking you sir,

*P. Ramalakshmi*

P.Ramalakshmi

Principal


PRINCIPAL

**CHINMAYA VIDYALAYA**

Kundanbagh, Begumpet. Hyd-16.

Affiliated to C.B.S.E, New Delhi.

Affiliation No: 3630042.



*Sandeepany Kailash*

CORRESPONDENT  
**CHINMAYA VIDYALAYA**

Sandeepany Kailash  
Kundhanbagh, Begumpet  
HYDERABAD - 500 016

**ANNEXURE -I**

(Annexure to G.O.Ms.No.56, Home (Ser.IV) Department, Dated:26.07.2019)


**Instructions to be followed for schools existing before 13.04.2009:**

**SELF CERTIFICATION FORM**

**Self Certification of Fire Safety Measures by School Management :**

**i) General Information for School Buildings of all categories i.e., A, B, C & D.**

Sl. No.	Details	
1	Date of the opening of the school building	<b>June 1993</b>
2	Name of the applicant	<b>P.Ramalakshmi</b>
3	Name and address of the School	<b>Chinmaya Vidyalaya</b> Kundanbagh, Begumpet, Hyderabad
4	Telephone Number and email of the applicant	<b>040-23418012</b> <b>principal</b>
5	Height of the building (in meters)	<b>10</b>
6	No of floors	<b>G+2 Floors</b>
7	Abutting Road width (in meters)	<b>6 Mts</b>
8	Built-up area of each floor in Sq.Mtrs Stilt ----- Ground ----- Floor1 ----- Floor2 -----	<b>3549.14 Sq. Mts</b> Ground - 1088.75 Sq.Mts 1 <sup>st</sup> Floor - 1104.36 Sq.Mts 2 <sup>nd</sup> Floor - 1356.03 Sq.Mts
9	Number of Staircases Staircase 1----- (width in meters) Staircase 2----- (width in meters)	<b>2 Nos.</b>  <b>1.5 Mts</b> <b>1.5 Mts</b>
10	Width of each Staircase	<b>1.5 Mts</b>
11	Open Spaces Front ----- (width in meters) Side 1----- (width in meters) Side 2----- (width in meters) Rear----- (width in meters)	Front - 7 Mts Side 1 - 7.39 Mts Side 2 - 8 Mts Rear - 7 Mts



*P. Ramalakshmi*  
Signature with date of  
School authority and Seal  
PRINCIPAL

**CHINMAYA VIDYALAYA**  
Kundanbagh, Begumpet, Hyd-16.  
Affiliated to C.B.S.E., New Delhi,  
Affiliation No. 3630042.

*A. Kasam*  
**CORRESPONDENT**  
**CHINMAYA VIDYALAYA**  
Sandeepany Kailash  
Kundanbagh, Begumpet  
HYDERABAD - 500 016



**A) School Buildings with Ground plus two floors and less than 15 Meters in height.**


Sl. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided
				Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.	Required	Yes 30 Nos
2	First Aid Hose Reel (IS 884:1985)	1 No for every 1000 square meter	Required	Yes 06 Nos
3	Terrace Tank over respective tower terrace	10000 Liters (5000 Liters additionally shall be provided if basement exceeds 200 square meters)	Required	10000 Lts Yes
4	Automatic Sprinkler System (IS 15105:2002) The IS standard may be downloaded from <a href="http://www.https://bis.gov.in/">www.https://bis.gov.in/</a>	To be installed in basement. If area of basement exceeds 200 square meters	N.A	
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 3.5 kg /cm <sup>2</sup>	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)	Required	Yes
<b>Additional Fire Safety Measures in lieu of deficiency in Setbacks.</b>				
1	Water Shower curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.		
2	Fire Brigade inlet	02 Nos		Yes

*P. Ramalakshmi*  
Signature with date of

School authority and Seal

CHINMAYA VIDYALAYA  
Kundhanbagh, Begumpet, Hyd-16

I/We, **K. Valli Prasanna** Correspondent hereby certify that the information furnished is correct and if it is noticed at any time that the information provided is false, we understand that our school affiliation may be cancelled by the Concerned Authority. We have installed fire safety measures as per the Annexure I and undertake to maintain the same in good working condition at all times.



*K. Valli Prasanna*  
Signature with date of  
School authority and Seal

Name & Designation:

**Correspondent**  
**CHINMAYA VIDYALAYA**  
**BEGUMPET, HYDERABAD**

*K. Valli Prasanna*  
**CORRESPONDENT**  
**CHINMAYA VIDYALAYA**  
Sandaepany Kailash  
Kundhanbagh, Begumpet  
HYDERABAD - 500 016